

PROFESSIONAL & PUMPS & water TREATMENT

800 Larchwood Crescent • Kingston – ON • K7P 2P9
T: (613) 561-7867 • johndjeffery@yahoo.ca
www.ppwt.ca

Well Test Report

Date: July 5 2016

Location: 18 Dragonfly lane

Client: _____

Well type: Drilled well Static level: 46 feet

Depth: 200 feet Current capacity: 230 gallons

Pumping rate: 7 gallons per minute

Drawdown after:

10 minutes	<u>24 feet</u>
20 minutes	<u>10 feet</u>
30 minutes	<u>10 feet</u>
40 minutes	<u>10 feet</u>
50 minutes	_____
60 minutes	_____

Recovery after:

10 minutes	<u>35 feet</u>
20 minutes	<u>full recovery</u>
30 minutes	_____
40 minutes	_____
50 minutes	_____
60 minutes	_____

Well is producing 5.5 gallons per minute at this time