

PROFESSIONAL PUMPS & water TREATMENT

800 Larchwood Crescent • Kingston – ON • K7P 2P9
T: (613) 561-7867 • ppwtsales@gmail.com
www.ppwt.ca

Well Test Report

Date: April 20 2018
Location: 633 Lake street. Delta
Client: _____
Well type: Drilled well Static level: 7 feet
Depth: 80 feet Current capacity: _____
Pumping rate: pumping at 9 gallons per minute
Drawdown after:
10 minutes Down 9 feet
20 minutes Down 6 feet
30 minutes Down 0 feet
40 minutes Down 0 feet
50 minutes Down 0 feet
60 minutes _____
Recovery after:
10 minutes Full recovery
20 minutes _____
30 minutes _____
40 minutes _____
50 minutes _____
60 minutes _____

Well is producing minimum 9 gallons per minute at this time

PROFESSIONAL PUMPS & water TREATMENT

800 Larchwood Crescent • Kingston – ON • K7P 2P9
T: (613) 561-7867 • ppwtsales@gmail.com
www.ppwt.ca

Page 2

Remarks

Date: April 20 2018

Water Quality

Raw water:

Iron 0.2 ppm
Hardness 10 grains
Sulphur 0 ppm
TDS 249 ppm
PH 7.5

Treated water:

Remarks:

Recommend well cap and
wire conduit for well

Recommend replacing galvanized
fittings on pressure tank

Recommend ultra violet light
on all well water supplies

Water softener would be
beneficial.

Well Contractor #7275

Professional Pumps and Water Treatment does not assume any liability for changes in quality or quantity of water on above mentioned well from the date of this report forward.

1100.